

**OFFICE: Sub-Divisional Engineer, Water Supply And
Sanitation, Sub-Division No. 4, Jalandhar**

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 630

Dated: 18/05/2026

It is certified that an inspection was Conducted by Water Supply & Sanitation Officials of Sub Division No. 4 Jalandhar at **Social Convent International School, Pattar Kalan, Kapurthala Road, Distt Jalandhar** on 07.05.2026 and found that the **Social Convent International School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **One year** .



**Sub Divisional Engineer
Water supply and sanitation
Sub divisional no. 4 jalandhar**

To

**Social Convent International School
Pattar Kalan, Kapurthala Road, Distt Jalandhar**

For Social Model Edu. Society (Regd.)


Authorized Signatory


PRINCIPAL

**SOCIAL CONVENT INTERNATIONAL SCHOOL
PATTER KALLAN, KPT.ROAD, JALANDHAR
AFF. TO C.B.S.E VIDE CODE NO. 1630556**

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com

To,

Social Convent International School, Pattar Kalan, Kapurthala Road, Jalandhar.
Distt. Jalandhar.


No.: DWTJAL/2627/00080 Dated : 14/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 574 Dated: 06/06/2026

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 13/05/2026. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Jalandhar

D/A : Test Report


Authorized Signatory
For, District water Testing Laboratory
Jalandhar

For Social Model Edu. Society (Regd.)


Authorized Signatory


PRINCIPAL
SOCIAL CONVENT INTERNATIONAL SCHOOL
PATTER KALLAN, KPT.ROAD, JALANDHAR
AFF. TO C.B.S.E VIDE CODE NO. 1630556

DISTRICT WATER TESTING LABORATORY, JALANDHAR
Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com



TC-14420

TEST REPORT			
Name & Address of Customer : Social Convent International School, Pattar Kalan, Kapurthala Road, Jalandhar. Distt. Jalandhar.		Customer Reference No.	No : 574 Dated : 06/06/2026
		Sample Submitted by	Sh. Manraj Singh (J.E.)
		Date of Sample Receipt	13/05/2026
		Analysis Starting Date	13/05/2026
		Analysis completion Date	14/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC14420260000190F	Sample Type :	Water
Test Report No.:	DWTJAL/2627/00080	Date of Issue :	14/05/2026
Registration no.:	DWTJAL/REG2627/00187	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL.
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Social Convent International School, Pattar Kalan, Kapurthala Road, Jalandhar.(P/Sub.) / NA
Village :	Pattar Kalan	Habitation :	Pattar Kalan
Block:	Jalandhar West	District :	Jalandhar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.66@26°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	364.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	258.56	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	317.52	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	72.27	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	33.33	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	32.30	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Jivesh Kumar
Microbiologist/Analyst
Authorized Signatory
For, District Water Testing Laboratory
Jalandhar

----- End of the Test Report -----

for Social Model Edu. Society (Regd.)

Authorized Signatory

PRINCIPAL
SOCIAL CONVENT INTERNATIONAL SCHOOL
PATTER KALLAN, KPT.ROAD, JALANDHAR
AFF. TO C.B.S.E VIDE CODE NO. 1630556

DISTRICT WATER TESTING LABORATORY, JALANDHAR

Water Supply and Sanitation Office, Near Bara Dari, Near DC Office, Jalandhar
dwtljalandhar@gmail.com



TC-14420

TEST REPORT			
Name & Address of Customer : Social Convent International School, Pattar Kalan, Kapurthala Road, Jalandhar. Distt. Jalandhar.		Customer Reference No. No : 574 Dated : 06/06/2026	
		Sample Submitted by Sh. Manraj Singh (J.E.)	
		Date of Sample Receipt 13/05/2026	
		Analysis Starting Date 13/05/2026	
		Analysis completion Date 14/05/2026	
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC144202600000190F	Sample Type :	Water
Test Report No.:	DWTJAL/2627/00080	Date of Issue :	14/05/2026
Registration no.:	DWTJAL/REG2627/00188	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL.
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Social Convent International School, Pattar Kalan, Kapurthala Road, Jalandhar.(R.O.) / NA
Village :	Pattar Kalan	Habitation :	Pattar Kalan
Block:	Jalandhar West	District :	Jalandhar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.13@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	172.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	141.4	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	125.44	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	26.70	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	14.28	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg-2 B By Calculation Method
11	Chloride(Cl)	15.20	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected T=Total
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

(Signature)

Mr. Jivesh Kumar
Microbiologist/Analyst
Authorized Signatory
For, District water Testing Laboratory
Jalandhar

End of the Test Report

For Social Model Edu. Society (Regd.)

(Signature)
Authorized Signatory

(Signature)
PRINCIPAL

SOCIAL CONVENT INTERNATIONAL SCHOOL
PATTAR KALLAN, KPT.ROAD, JALANDHAR
AFF. TO C.B.S.E VIDE CODE NO. 16/10/95